

Fastlane® GlassWing

Optical Barrier Turnstile

Architectural & Engineering Specification

I – GENERAL

1.01 REFERENCES

- A. The Power supply unit (PSU) shall be certified under CE, UL 60950-1, second edition and CSA C22.2 No. 60950-1-07, second edition, to provide 24Vdc “class 2” supplies as part of a Fastlane Turnstile system.
- B. The Fastlane Glasswing turnstile system shall be available as a UL listed variant to UL 2593, Outline of Investigation for Motor Driven Turnstile Operators and Systems; CSA C22.2 No. 247, Operators and Systems of Doors, Gates, Draperies, and Louvres.
- C. The Glasswing Optical Barrier Turnstile shall be CE marked in accordance with following the European Directives.
 - 1. Electromagnetic Compatibility EU Directive 2004/108/EC
 - 2. Low Voltage EU Directive 2006/95/EC
 - 3. Machinery Directives EU Directive 2006/42/EC

1.02 QUALITY ASSURANCE

- A. Manufacturer must operate a Quality Management System that meets the ISO 9001:2008. International Standard for design, development, and manufacturing activities, including associated software products.
- B. Manufacturer shall be a global supplier specializing in the design and manufacture of automatic security turnstiles with a minimum of twenty (20) years’ experience.
- C. Installer shall have a minimum of three (3) years’ experience installing Fastlane turnstiles or similar equipment or shall supply a manufacturer-trained technician for Site Certification &

Training following installation of the Fastlane Glasswing Optical Turnstiles with Retracting Glass Wings.

1.03 SUBMITTALS

- A. Submit manufacturer's product literature including datasheet and drawing pack for specific model, including options.
- B. Provide high resolution photo.
- C. Provide, upon request, Glasswing Installation & Maintenance manual.
- D. Provide, upon request, site specific drawings detailing product placement, arrangement and wiring.

1.04 DELIVERY, STORAGE, AND HANDLING

- A. Deliver equipment and materials to specified location in manufacturer's packaging undamaged, complete with installation instructions.
- B. Store off ground, under cover, protected from weather and construction activities. For periods of extended storage the equipment will be kept in an environment that regulates temperature and humidity.
- C. Use forklift, pallet jack, or specified number of personnel for moving equipment, observing manufacturer's safety instructions at all times.

1.05 PROJECT/SITE CONDITIONS

- A. Install Fastlane Glasswing Optical Turnstiles with Glass Panels on level, finished floor, and in strict accordance with manufacturer's installation chapter in the provided Installation & Maintenance manual.
- B. Install Fastlane Glasswing Optical Turnstile on manufacturer-supplied Floor Protector System to rest on a level finished floor.

1.06 WARRANTY

Manufacturer's standard form in which manufacturer agrees to repair or replace components of optical turnstile system that fail in materials or workmanship within specified warranty period. Failures include, but are not limited to, the following: faulty circuit boards (PCB), infrared beams, and mechanical components. Warranty Periods: Standard 1 year from date of shipment, 2 years from installation with on-line product registration using manufacturer's Fastlane *Connect* remote services, or 3 years with purchase of Site Certification services. Further warranty extensions may be available upon request.

PART II - PRODUCTS

2.01 MANUFACTURER

- A. Integrated Design Ltd
- B. Smarter Security, Inc. is the exclusive distributor in North America and also distributes Fastlane products in Central and South America.
110 Wild Basin Road, #200, Austin, TX 78746, USA
Tel: (512) 328-7277, Fax: (512) 328-7280, Web: www.smartersecurity.com

2.02 PRODUCT

- A. Fastlane Glasswing with Retracting Glass Panels, NO SUBSTITUTIONS. Include the following options: SmarterLobby integration software, TCP/IP connections, Fastlane Desktop Remote Control Unit, Fastlane Touchscreen Remote, or Fastlane Connect.
- B. Turnstiles MUST be able to integrate with lobby integration software (such as Smarter Security's SmarterLobby) in order to consider more than just credentials. Data/behaviors from other systems can therefore factor into turnstile permission decisions.

2.03 CONSTRUCTION

- A. Exterior:
 - 1. End Panels: stainless steel 304 grade 240 grit (Satin No. 4) horizontal grain (standard).
 - 2. Side Panels: stainless steel 304 grade 240 grit (Satin No. 4) horizontal grain (standard) with polycarbonate filter windows for the infrared beams.
 - 3. Encasement: stainless steel 304 grade 240 grit (Satin No. 4) horizontal grain (standard)
- B. Interior Chassis:
 - 1. Chassis framework must be black satin, powder-coated mild steel
 - 2. 4 No. 10mm mounting studs are required to secure the H Mounting Plate to the floor substrate, the baseplate secures to the H mounting plate using 4 No. M10 bolts.
- C. Decorative Tops:
 - 1. 10mm Black Quartz Corian®
 - 2. Optional - 10mm Low Iron Clear Toughened Glass (EN 14179 / ANSI 97.1) with a white underside finish
 - 3. Optional - Stainless steel 304 grade 240 grit (Satin No. 4) horizontal grain with optional frosted acrylic inset into panel for reader mounting locations.
 - 4. Optional – Custom materials e.g. 20-25mm thick Stone
- D. Glass Wings:

Revision: 01/29/2025

Version: SP-24-2

1. 10mm Toughened Safety Glass (Heat Soaked) to EN 14179 / ANSI 97.1.
 2. Barrier Height 928mm
- E. Card Reader Window:
1. Optional frosted acrylic inset into end panel
- F. Turnstile Status Display
1. Located on the right-hand side of each lane viewed from the entrance/exit
 2. The Indicator is provided by LEDs diffused through frosted clear acrylic inset into the top of the end panel, dimensions vary by end panel type and pedestal width.
- G. Enclosure: Compact Width Model
1. Dimensions
 - a. Elliptical end panel model Length 1500mm, Width 308mm, Height 960mm
 - b. Square end panel model Length 1252mm, Width 308mm, Height 960mm
 2. Pedestal weight (Interlane) 80Kg
- H. Enclosure: Standard Width Model
1. Dimensions
 - a. Elliptical end panel model Length 1500mm, Width 372mm, Height 960mm
 - b. Square end panel model Length 1252mm, Width 372mm, Height 960mm
 2. Pedestal weight (Interlane) 110Kg
- I. Enclosure: Wide Width Model
1. Dimensions
 - a. Elliptical end panel model Length 1500mm, Width 452mm, Height 960mm
 - b. Square end panel model Length 1252mm, Width 452mm, Height 960mm
 2. Pedestal weight approx. 120Kg
- J. Unit enclosure shall provide an Ingress Protection rating of IP20.

2.04 EQUIPMENT

Revision: 01/29/2025
Version: SP-24-2

- A. General: Two or more adjacent pedestals utilizing pulsed infrared beams to create an invisible electronic field between pedestals, monitoring the passage of individuals entering and leaving a facility, discriminating between people and nuisances (such as common briefcases, umbrellas, and rolling carts); with retracting glass wings to physically deter unauthorized individuals from passing through the lane. A normally close mode is used to deter an unauthorized user from pushing through. Standard Lane widths of 550mm, 660mm and 914mm are available using the Compact, Standard and Wide enclosure widths respectively. All calibrations, feature set selections and diagnostics are built into the unit managed on board by the relevant processor cards. Must not require a Windows based PC to operate.

- B. Types of units: The system shall consist of a Transmit Pedestal (TX) and a Receive Pedestal (RX) to provide a single lane, and Interlane Pedestals (INT) to form additional lanes between the RX and TX pedestals.

- C. Capabilities [System Requirements]:
 - 1. Detect and deter unauthorized persons from entering into the protected area.
 - 2. Detect unauthorized persons more than 5 mm at waist height behind an authorized person that is, "tailgating" or "piggybacking."
 - 3. Detect direction of movement, that is, entry and exit.
 - 4. Verify entry into the protected area following authorization.
 - 5. Provide alarm outputs on detection of a violation by means of:
 - a. Local sounders and indicators
 - b. Remote sounder output
 - 6. Operate in bi-directional, single direction, no entry or free access modes.
 - 7. Minimize false alarms through the use of infrared beams connected to intelligent detection algorithms.
 - 8. Process a high number of people without security guard intervention, unless access is rejected by the system or a system anomaly occurs.
 - 9. Ensure a fast throughput, up to one person per second, subject to the access control system.
 - 10. Buffering multiple inputs from an access control system to maximize throughput.

11. Easy to use.
12. Allow free movement for wheelchair users with DDA width lanes.
13. Allow safe emergency egress through a fire alarm input to open the glass panels.
14. Entry and exit with an authorized card, biometric, or other credential.
15. Entry and exit that is unauthorized causing an alarm.
16. Authorized card being read by the system but no entry or exit taking place using an optional alarm configuration.
17. Card presented for entry but exit occurring causing an alarm.
18. Card presented for exit but entry occurring causing an alarm.
19. Obstruction of an infrared beam path causing an alarm.
20. Create an alarm for a person forcing the glass wings back into the pedestal, forced entry.

D. Fastlane Optical System

1. Intelligently monitored infrared beam matrix: Up to 32 beam paths per lane.
 - a. IR Beams with distributed processing for maximum signal analysis. Every 4 infrared beam paths have a dedicated microprocessor coupled to a custom-designed system controller. These technologies work together to create an “entity management” system that ‘thinks’ in real time to accurately position the size, shape, and speed of individual entities in the lane.
 - b. Superfluous user behavior tolerated by the software without generating an alarm condition due to:
 - i. Partial passage through the beams and moving back out again.
 - ii. Hesitation in the beam field for less than a pre-selected number of seconds.
 - iii. Presenting a card for authorization while within the beam-field, but before completing passage through it.

2. Access request transaction speed: Time delay of no greater than 100ms in signaling passage through the beams and readying the turnstile for the next user except when a greater delay is caused by the attached access control system.
 - a. The optical system must be capable of throughput of up to 1 person per second.
 - b. The system throughput including barrier operation and access control system is better than 40 persons per minute.
3. Glass Panel Control Beams: 4 direct beam paths reduce the velocity or stop the barrier movement in the event that a user is in the path of an operating barrier.
4. Visitor Management System: Allows an unlimited number of people to pass through the lane. Once the visitors have entered and the system no longer sees anyone entering or exiting for 3 seconds, the glass panels return to the closed position.

E. Operating Modes

1. Optical turnstile mode – whereby the glass panel barriers are positioned to the exit end of the lane and the system operates as an optical-only turnstile.
2. Normally closed mode – whereby the barriers are closed (centered within the lane) and open away from the requested and authorized direction of travel.
3. Visitor entry mode – where the turnstile opens upon visitor request and allows free travel through the turnstile without issuing an alarm. Once the visitors have entered and the system no longer sees anyone entering or exiting for 3 seconds, the beam operations return to their original security setting.
4. Emergency – unit must have a dedicated input for integration with a fire control panel to receive fire alarm signals. When the emergency signal is activated, glass barriers will open in the exit direction and remain open to allow unobstructed passage. Once the emergency signal is deactivated, the unit must return to the operating mode immediately preceding the alarm.
5. Power Fail – unit must have glass wing barriers that open automatically with internal auxiliary power option in the event of power failure. Without this option, barriers may be easily pushed into the pedestals. Once power is restored, unit must return to the operating mode immediately preceding the event.

F. Inputs:

1. Entry Request: Normally Open dry contract. Closing on request for <1 second
2. Exit Request: Normally Open dry contract. Closing on request for <1 second
3. Entry Visitor Request: Normally Open momentary closing switch contacts
4. Exit Visitor Request: Normally Open momentary closing switch contacts
5. Ethernet port

G. Outputs:

1. Voltage-free relay contacts rated 24Vdc @ 500mA for the following functions for alarm indicators, and to provide turnstile and entry and exit door emulation.
2. Output to Access control System:
 - a. Access monitoring (used as confirmation of access after authorization)
 - i. Entry: Normally closed (opening for 1s)
 - ii. Exit: Normally closed (opening for 1s)
 - b. Alarm 1: Normally closed (opening for a minimum of 1s)
 - c. Alarm 2: Normally closed (opening for 1s)
3. Two-Stage Audio/Visual Alarm System
 - a. First stage notifies user and guard that someone has entered the lane without authorization.
 - i. Allows user to back up and attempt authorization, before going into a full alarm.
 - ii. Guard becomes aware that a lane violation may occur.
 - b. Second stage notifies user and guard that someone has passed through the lane without authorization.
 - i. Notifies the user that they have passed through the lane without authorization.
 - ii. Guard becomes aware that a lane violation has occurred and to take appropriate action.

4. Audible Alarms: Provide for each lane triggered in an alarm condition.
 - a. Local alarm sounders.
 - b. Relay Contact: utilized to trigger external alarm systems.
 - c. Secondary sounder that will be triggered in the event of “forced entry,” that is, an individual tries to push through the glass panels after an alarm event.
 5. Status Display: Provide for each lane a visual indication of the status of the lane.
 - a. Standby – White
 - b. Please Proceed – Green
 - c. Red – Lane closed
 - d. Flashing Red - Alarm.
- H. Power Requirements:
1. Pedestal: Low voltage 24Vdc supply current 1.3A maximum per barrier
 - a. Hazardous voltage must not be present at pedestal to ensure user safety.
 2. Power Supply Unit:
 - a. PSU to be remotely installed.
 - b. PSU Wall Mounted Metal Enclosure, approximately 330mm long 200mm wide by 136mm tall.
 - c. PSU input voltage 100Vac to 240Vac at 60/50Hz, connection by 5A fused spur.
- I. Wiring Requirements:
1. Pedestal Wiring: Each Transmit and Receive Pedestals (pedestals with a single motor drive units) requires an independent 24Vdc supply using a minimum conductor cross sectional area of 16 AWG (1.5mm²) e.g. Belden 8620 or similar. Interlane Pedestals (pedestals with dual motor drive units) require two independent 24Vdc supplies.
 2. Fastlane System Interconnect: A CAT5 cable (provided) between the Transmit and Receive or Interlane pedestals for each lane to facilitate power, synchronization of infrared beams, and motor driver communication.

3. Earth Cables: earth connection from each pedestal to ground, using a green/yellow sleeved cable with a minimum conductor cross sectional area of 18 AWG (1mm²).
4. Card Readers: as required by access control system manufacturer (typically mounted to pedestal on the right-hand side of the lane entrance).
5. Access Control Lane Integration: as required by access control system manufacturer. (typically, 10-conductor cable with a minimum conductor cross sectional area of 0.35mm² (22 AWG))
6. Emergency Input: FP200 or similar from the Fire Panel Normally Closed relay contacts (or 24V signal) to each Interlane and Receive Pedestal.
7. Optional - IP Connect Multilane or Touchscreen: a twisted pair plus screen e.g. Belden 8302, between Receive and Interlane pedestals (for up to 8 lanes) and either an IP Connect Multi-Lane controller or Touchscreen for RS485 communications with the lanes.
8. Optional - Remote Control: 8-conductor cable with a minimum conductor cross sectional area of 22 gage (0.35mm²). Typically to reception desk or security room.
9. TCP/IP cables: An Ethernet cable is required between each Fastlane processor board and a remote location for a hub. The hub may either be connected to the Internet via a router or mobile network connection for remote support.

2.05 FACTORY TESTING

- A. Fastlane Glasswing Optical Turnstile with retracting glass wings shall be fully assembled and staged as a system at the factory to accommodate soak testing for a period of 48 hours at a minimum to ensure proper operation and electrical connectivity. System shall be inspected for mechanical, electrical and aesthetic condition prior to packaging and shipment.

2.06 SECURITY EQUIPMENT

- A. Card Readers: System compatible with major access control technologies for owner-provided card readers of suitable dimensions to be mounted onto pedestals. Must support integration of multiple card readers at each mounting location by manufacturer.
 1. Card Reader Mounting at pedestal ends:
 - a. Under, or surface-mounted on Corian decorative top part
 - b. Option at pedestal ends surface-mounted.

B. Manufacturer-supplied Accessories

1. Touchscreen Remote Control: Optional

- a. Operational Mode Control through Touchscreen control.
 - i. Optical turnstile mode.
 - ii. Normal mode.
 - iii. Visitor entry
- b. Provide Visitor Buttons allowing an unlimited number of visitors to pass through the lane in the entry or exit direction.
 - i. Once the visitors have entered and the system no longer sees anyone entering or exiting for 3 seconds, the beam operations return to their original security setting.
- c. Provide indication designed to illuminate when an alarm is activated to provide a visual indication of the lane alarm status.
- d. Provide real time population count.

2. Remote Console: Optional

- a. Provide Visitor Buttons allowing an unlimited number of visitors to pass through the lane in the entry or exit direction
- b. Provide Alarm Indication
- c. Key switch

3. IP Connect:

The turnstiles will provide individual TCP/IP addresses when connected to a computer network to enable remote control of function and operation, along with remote monitoring facilities.

4. IP Connect Multi Lane: Optional

A Multi-lane controller is available to remotely control and monitor up to 8 lanes over TCP/IP networks.

5. Floor Protectors: Optional. Modular system designed to support turnstile pedestals without need for drilling mounting bolts into floor or running a conduit under floor between pedestals for cables.
6. Fastlane Infill System: Optional. A series of decorative glass modular panels that guide users in a desired direction, while complimenting turnstile design.

A Product use:

1. Quiescent Energy Consumption per lane: 230 kW hours per annum
2. Maintenance: Annual Interval 12-month interval minimum.
3. Indoor use only.

2.08 SUSTAINABILITY

A. The product is recyclable at end of life. The following materials are to be distributed to appropriate recycling facilities resulting in a very low residual waste of non-recyclable material.

1. Stainless Steel (sheet material 1mm to 1.5mm thickness)
2. Mild Steel (sheet material 1.2 to 3mm thickness)
3. Plastics
4. Glass
5. Printed circuit boards
6. Special components e.g. gearboxes and motors, power supply modules

B. The product is supplied on reusable plastic pallets with recyclable carton packaging comprising of the following materials.

1. Corrugated fiber board
2. Foam
3. Polyethylene

PART III – EXECUTION

3.01 SITE EXAMINATION

- A. Inspection: Installer / Integrator shall examine the installation and advise the contractor of any site conditions unacceptable for proper installation of product.
1. Finished floor substrate must be dead level within the footprint of the turnstile.
 2. Main supply service for power supply and low voltage power out & control wiring must be installed.
- B. Installation: Turnstiles shall be installed in accordance with manufacturer's Fastlane Installation & Maintenance manual.
- C. Setup & Adjustment: Installer / Integrator shall perform initial equipment electronic adjustments to ensure proper performance after installation.
- D. Instruction: Installer / Integrator with a minimum of 3 years experience installing Fastlane optical turnstiles shall furnish operator training for end-user or provide for Smarter Security Limited Site Certification & Training services during installation.
- E. Cleaning: Clean metal, acrylic and glass surfaces carefully after installation to remove excess caulk, dirt, and labels.
- F. Maintenance: Maintain the equipment according to the manufacturer's instructions.

[Smarter Security reserves the right to change this specification at any time without notice.]

END OF SECTION

Version History

Issue	Date	Change	ref
A0	24/02/14	First release	-
B0	02/03/15	Added maintenance requirement - Updated manufacturer address - Correction to Alarm 1 and 2.	CN2461